



Firmware for MGate 5102-PBM-PN Series Release Notes

Version: v2.0	Build: Build 18012622
Release Date: Mar 21, 2018	

Applicable Products

MGate 5102-PBM-PN, MGate 5102-PBM-PN-T

Supported Operating Systems

N/A

New Features

N/A

Enhancements

- Supports security features based on IEC-62443.
- Simplified telnet/ssh/serial console settings.
- Accessible IP List supports denying Web/Telnet/SSH console access.

Bugs Fixed

- Issue importing SIE180BB.GSD (Siemens SIMEAS P).
- Issue parsing user parameters with WAGO 750-303.
- Incorrect topology display due to forwarding LLDP frames to another LAN port.

Changes

N/A

Notes

N/A



Version: v1.3	Build: Build 16070411
Release Date: Sep 09, 2016	

Applicable Products

MGate 5102-PBM-PN, MGate 5102-PBM-PN-T

Supported Operating Systems

N/A

New Features

N/A

Enhancements

- Supports Name/Contact/Location settings for MXconfig.
- Supports PROFIBUS module names over 32 characters long. MGate 5102-PBM-PN will truncate the displayed module name when its length is over the 32-character limitation specified by the PROFIBUS GSD specification.
- Changed the PROFIBUS Watchdog default value to 600 ms for baudrates of 500 kbit/sec or higher.
- HTTPS web server only supports TLSv1.0 to protect against DROWN attacks.
- Patched glibc to protect against GHOST vulnerability.
- The version of the exported GSDML file was updated to version 2.2.

Bugs Fixed

- MGate could not communicate with some specific PROFIBUS slave devices due to only supporting a portion of the device's user parameters.
- Returned the wrong IP/netmask/gateway when SNMP read private MIB under DHCP mode.
- MGate 5102-PBM-PN could not communicate with some specific PROFIBUS slave devices due to incorrect parsing of a module's user parameter data.
- MGate 5102-PBM-PN could not communicate with ABB M102 slave (with ABB_08DD.gsd.)

Changes

N/A

Notes

N/A



Version: v1.2	Build: Build 13083010
Release Date: N/A	

Applicable Products

MGate 5102-PBM-PN, MGate 5102-PBM-PN-T

Supported Operating Systems

N/A

New Features

N/A

Enhancements

- Supports "DCP-Signal" function.
- Passed PROFINET certification.
- Modified LLDP transmit interval to 5 seconds with TTL value 20.

Bugs Fixed

- Cyclic I/O data error when the input and out slot are configured as interlaced.
- Return status of the second AR connection was not correct.
- PROFIBUS module handling of SLAVE_INPUTS_CHANGED event.

Changes

N/A

Notes

N/A



Version: v1.1	Build: Build 13031216
Release Date: N/A	

Applicable Products

MGate 5102-PBM-PN, MGate 5102-PBM-PN-T

Supported Operating Systems

N/A

New Features

N/A

Enhancements

- Shows full model name in the header after logging in to the telnet/serial console.

Bugs Fixed

N/A

Changes

N/A

Notes

N/A



Version: v1.0	Build: Build 13020716
Release Date: N/A	

Applicable Products

MGate 5102-PBM-PN, MGate 5102-PBM-PN-T

Supported Operating Systems

N/A

New Features

- First release.

Enhancements

N/A

Bugs Fixed

N/A

Changes

N/A

Notes

N/A