



Firmware for ioLogik 4000 Series (E4200) Release Notes

Version: v1.5	Build: Build14011615
Release Date: Jan 16, 2014	

Applicable Products

ioLogik E4200

Supported Operating Systems

N/A

New Features

N/A

Enhancements

- Mail address setting can without Login name & Login Password information.
- Improve default gateway setting in Modular ioAdmin for ioLogik E4200 firmware v1.4 or later only.

Bugs Fixed

- RTC Power on initial.
- Fix that flash could crash while power cycling.
- Fix default gateway setting issue on web console.

Changes

N/A

Notes

- Improvement of default gateway setting works with the Modular-ioAdmin v1.5 or later only.



Version: v1.4	Build: Build12091212
Release Date: N/A	

Applicable Products

ioLogik E4200

Supported Operating Systems

N/A

New Features

N/A

Enhancements

- Add CGI command status in web console.
- Improve default gateway setting in Modular ioAdmin and web console.

Bugs Fixed

- Fixed DNS refresh cause fresh data error.
- Fixed Webpage cannot show data while Flash data updating.
- Fixed AOPC & web console cannot be used simultaneously.

Changes

N/A

Notes

- Improvement of default gateway setting works with the Modular-ioAdmin v1.5 or later only.



Version: v1.3	Build: Build11060216
Release Date: N/A	

Applicable Products

ioLogik E4200

Supported Operating Systems

N/A

New Features

N/A

Enhancements

- Added Modbus Address Function Code=0x08 for “ECHO” function.
- Increased the maximum length of the email account and password fields in Click&Go to 39 characters.

Bugs Fixed

- The text between '<' and '>' should not be removed in message content.
- Triggering remote action in every specific time should not be triggered again during this period of time.
- Removed Modbus/TCP ID checking mechanism.

Changes

N/A

Notes

- This firmware version works with the Modular-ioAdmin v1.3 or later only.